



Test Report: IDPC-45-700

45W Constant Current Mode LED Driver

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test





■ RELIABILITY TEST

Environment Test

DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	CONSTANT CURRENT REGION	38V~64V	I/P: 230VAC O/P: LED MODE Ta: 25°C	31V~67V
2	CURRENT RIPPLE	5% max@rated current	I/P: 230VAC O/P: FULL/MIN LOAD Ta: 25°C	3.29%
3	CURRENT TOLERANCE	±7%	I/P: 230VAC O/P: FULL/MIN LOAD Ta: 25°C	±2.85%
4	OPEN CIRCUIT VOLTAGE (max)	84V	I/P: 230VAC O/P: NO LOAD Ta: 25°C	80.01V
5	OVER/UNDERSHOOT TEST	<±5 %	I/P: 230VAC O/P: FULL LOAD Ta: 25°C	<5 %
6	SET UP TIME	500ms/230VAC 1200ms/115VAC	I/P: 230 VAC I/P: 115 VAC O/P: FULL LOAD Ta: 25°C	368ms/230VAC 390ms/115VAC
INPUT=230VAC/50HZ @ FULL LOAD CH1: Output Voltage CH2: AC Input Voltage 		INPUT=115VAC/60HZ @ FULL LOAD CH1: Output Voltage CH2: AC Input Voltage 		
7	AUXILIARY DC OUTPUT (A-Type only)	Nominal 12V (deviation 11.4~12.6) @50mA	I/P: 230 VAC O/P:FULL LOAD	12.01 V


<p>8</p>	<p>DIMMING TEST(For Blank -Type)</p>	<ul style="list-style-type: none"> Output constant current level can be adjusted by applying one of the two methodologies between DIM+ and DIM-: 0 ~ 10Vdc, or 10V PWM signal. Direct connecting to LEDs is suggested. It is not suitable to be used with additional drivers. ◎ Applying additive 0 ~ 10VDC  <p>“DO NOT connect "DIM- to Vo-”</p> <ul style="list-style-type: none"> ◎ Applying additive 10V PWM signal (frequency range 300Hz ~ 3KHz):  <p>“DO NOT connect "DIM- to Vo-”</p>	  <p>Note : 1. Min. dimming level is about 8% and the output current is not defined when 0% < Iout < 8%. 2. The output current could drop down to 0% when dimming input is about 0Vdc or 10V PWM signal with 0% duty cycle.</p> <p>TEST RESULT: I/P: 230 VAC; Ta: 25°C</p> <table border="1" data-bbox="295 1299 1532 1758"> <tr> <td rowspan="3">1</td> <td>Dimming voltage</td> <td>0V</td> <td>1V</td> <td>2V</td> <td>3V</td> <td>4V</td> <td>5V</td> <td>6V</td> <td>7V</td> <td>8V</td> <td>9V</td> <td>10V</td> </tr> <tr> <td>Output Current</td> <td>0A</td> <td>0.060</td> <td>0.147</td> <td>0.217</td> <td>0.289</td> <td>0.360</td> <td>0.433</td> <td>0.505</td> <td>0.573</td> <td>0.645</td> <td>0.710</td> </tr> <tr> <td>Percentage of rated current</td> <td>0.00%</td> <td>8.57%</td> <td>21.00%</td> <td>31.00%</td> <td>41.29%</td> <td>51.43%</td> <td>61.86%</td> <td>72.14%</td> <td>81.86%</td> <td>92.14%</td> <td>101.43%</td> </tr> <tr> <td rowspan="3">2</td> <td>Dimming Duty cycle</td> <td>0%</td> <td>10%</td> <td>20%</td> <td>30%</td> <td>40%</td> <td>50%</td> <td>60%</td> <td>70%</td> <td>80%</td> <td>90%</td> <td>100%</td> </tr> <tr> <td>Output Current</td> <td>0A</td> <td>0.060</td> <td>0.149</td> <td>0.220</td> <td>0.290</td> <td>0.360</td> <td>0.431</td> <td>0.500</td> <td>0.571</td> <td>0.641</td> <td>0.704</td> </tr> <tr> <td>Percentage of rated current</td> <td>0.00%</td> <td>8.57%</td> <td>21.29%</td> <td>31.43%</td> <td>41.43%</td> <td>51.43%</td> <td>61.57%</td> <td>71.43%</td> <td>81.57%</td> <td>91.57%</td> <td>100.57%</td> </tr> </table> <p>TEST RESULT: OK</p>	1	Dimming voltage	0V	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V	Output Current	0A	0.060	0.147	0.217	0.289	0.360	0.433	0.505	0.573	0.645	0.710	Percentage of rated current	0.00%	8.57%	21.00%	31.00%	41.29%	51.43%	61.86%	72.14%	81.86%	92.14%	101.43%	2	Dimming Duty cycle	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%	Output Current	0A	0.060	0.149	0.220	0.290	0.360	0.431	0.500	0.571	0.641	0.704	Percentage of rated current	0.00%	8.57%	21.29%	31.43%	41.43%	51.43%	61.57%	71.43%	81.57%	91.57%	100.57%
1	Dimming voltage	0V	1V		2V	3V	4V	5V	6V	7V	8V	9V	10V																																																																
	Output Current	0A	0.060		0.147	0.217	0.289	0.360	0.433	0.505	0.573	0.645	0.710																																																																
	Percentage of rated current	0.00%	8.57%	21.00%	31.00%	41.29%	51.43%	61.86%	72.14%	81.86%	92.14%	101.43%																																																																	
2	Dimming Duty cycle	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%																																																																	
	Output Current	0A	0.060	0.149	0.220	0.290	0.360	0.431	0.500	0.571	0.641	0.704																																																																	
	Percentage of rated current	0.00%	8.57%	21.29%	31.43%	41.43%	51.43%	61.57%	71.43%	81.57%	91.57%	100.57%																																																																	
<p>9</p>	<p>DALI DIMMING OPERATION (primary side: for DA-Type)</p>	<p>※DALI Interface ·Apply DALI signal between DA+ and DA-. ·DALI protocol comprises 16 groups and 64 addresses. ·First step is fixed at 8% of output.</p> <p>I/P: 230 VAC O/P: DIMMING TEST Ta: 25°C TEST RESULT: OK</p>																																																																											

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	INPUT VOLTAGE RANGE	90VAC~295VAC	I/P: TESTING O/P: FULL LOAD Ta: 25°C	87V~305V
			I/P: (1)LOW-LINE-3V=87 V HIGH-LINE+10V=305 V O/P: FULL/MIN LOAD ON: 30 Sec OFF: 30 Sec 10MIN (2)230VAC ON: 0.5 Sec OFF: 0.5 Sec 20MIN (POWER ON/OFF NO DAMAGE)	TEST: OK
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P: 90 VAC ~295 VAC O/P: FULL~MIN LOAD Ta: 25°C	TEST: OK
3	AC CURRENT	0.6A/115VAC 0.4A/230VAC 0.3A/277VAC	I/P: 115 VAC I/P: 230 VAC I/P: 277 VAC O/P: FULL LOAD Ta: 25°C	I =0.562A/ 115VAC I =0.234A/ 230VAC I =0.200A/ 277VAC
4	LEAKAGE CURRENT	< 0.75mA / 277VAC	I/P: 277 VAC O/P: NO LOAD Ta: 25°C	L-CASE: 0.0029 mA N-CASE: 0.0029 mA
5	NO LOAD/STANDBY POWER CONSUMPTION	< 0.5W for Blank-Type < 1.2W for A-Type < 0.5W for DA-Type	I/P: 230VAC O/P: NO LOAD Ta: 25°C	0.349W for Blank-Type 0.463W for A-Type 0.446W for DA-Type
6	INRUSH CURRENT(Typ)	230V/ 30A Twidth =100 us measured at 50% Ipeak COLD START	I/P: 230 VAC O/P: FULL LOAD Ta: 25°C	I =22.2A/ 230VAC Twidth =80us

INPUT=230VAC/50HZ @ FULL LOAD

CH1: AC Input Voltage CH2: Input current



7	EFFICIENCY(Typ)	85%	I/P: 230VAC O/P: FULL LOAD Ta: 25°C	89.2%																												
<p>EFFICIENCY vs LOAD</p> <table border="1"> <caption>Efficiency vs Load Data</caption> <thead> <tr> <th>LOAD</th> <th>277V</th> <th>230V</th> <th>115V</th> </tr> </thead> <tbody> <tr> <td>50%</td> <td>83.0</td> <td>84.0</td> <td>84.5</td> </tr> <tr> <td>60%</td> <td>85.0</td> <td>86.0</td> <td>86.0</td> </tr> <tr> <td>70%</td> <td>86.5</td> <td>87.5</td> <td>87.0</td> </tr> <tr> <td>80%</td> <td>88.0</td> <td>88.5</td> <td>87.5</td> </tr> <tr> <td>90%</td> <td>88.5</td> <td>89.0</td> <td>88.0</td> </tr> <tr> <td>100%</td> <td>89.0</td> <td>89.5</td> <td>88.0</td> </tr> </tbody> </table>					LOAD	277V	230V	115V	50%	83.0	84.0	84.5	60%	85.0	86.0	86.0	70%	86.5	87.5	87.0	80%	88.0	88.5	87.5	90%	88.5	89.0	88.0	100%	89.0	89.5	88.0
LOAD	277V	230V	115V																													
50%	83.0	84.0	84.5																													
60%	85.0	86.0	86.0																													
70%	86.5	87.5	87.0																													
80%	88.0	88.5	87.5																													
90%	88.5	89.0	88.0																													
100%	89.0	89.5	88.0																													
8	POWER FACTOR	0.95/ 115VAC 0.92/ 230VAC 0.90/ 277VAC	I/P: 115 VAC I/P: 230 VAC I/P: 277 VAC O/P: FULL LOAD Ta: 25°C	PF=0.99/ 115VAC PF=0.978/ 230VAC PF=0.95/ 277VAC																												
<p>P.F vs LOAD</p> <table border="1"> <caption>P.F vs Load Data</caption> <thead> <tr> <th>LOAD</th> <th>277V</th> <th>230V</th> <th>115V</th> </tr> </thead> <tbody> <tr> <td>50%</td> <td>0.87</td> <td>0.94</td> <td>0.99</td> </tr> <tr> <td>60%</td> <td>0.90</td> <td>0.95</td> <td>0.99</td> </tr> <tr> <td>70%</td> <td>0.92</td> <td>0.96</td> <td>0.99</td> </tr> <tr> <td>80%</td> <td>0.93</td> <td>0.97</td> <td>0.99</td> </tr> <tr> <td>90%</td> <td>0.94</td> <td>0.97</td> <td>0.99</td> </tr> <tr> <td>100%</td> <td>0.95</td> <td>0.98</td> <td>0.99</td> </tr> </tbody> </table>					LOAD	277V	230V	115V	50%	0.87	0.94	0.99	60%	0.90	0.95	0.99	70%	0.92	0.96	0.99	80%	0.93	0.97	0.99	90%	0.94	0.97	0.99	100%	0.95	0.98	0.99
LOAD	277V	230V	115V																													
50%	0.87	0.94	0.99																													
60%	0.90	0.95	0.99																													
70%	0.92	0.96	0.99																													
80%	0.93	0.97	0.99																													
90%	0.94	0.97	0.99																													
100%	0.95	0.98	0.99																													
9	TOTAL HARMONIC DISTORTION	THD < 20% (@load ≥ 60% / 115VAC, 230VAC; @load ≥ 75% / 277VAC)	I/P: 115 VAC / 60% LOAD I/P: 230 VAC / 60% LOAD I/P: 277 VAC / 75% LOAD Ta: 25°C	THD=5.79% @60% load / 115VAC THD=7.87% @60% load / 230VAC THD=9.84% @75% load / 277VAC																												
<p>THD vs LOAD</p> <table border="1"> <caption>THD vs Load Data</caption> <thead> <tr> <th>LOAD</th> <th>277V</th> <th>230V</th> <th>115V</th> </tr> </thead> <tbody> <tr> <td>50%</td> <td>10.0</td> <td>7.8</td> <td>6.0</td> </tr> <tr> <td>60%</td> <td>9.8</td> <td>7.6</td> <td>5.8</td> </tr> <tr> <td>70%</td> <td>9.6</td> <td>7.4</td> <td>5.6</td> </tr> <tr> <td>80%</td> <td>9.4</td> <td>7.2</td> <td>5.4</td> </tr> <tr> <td>90%</td> <td>9.2</td> <td>7.0</td> <td>5.2</td> </tr> <tr> <td>100%</td> <td>9.0</td> <td>6.8</td> <td>5.0</td> </tr> </tbody> </table>					LOAD	277V	230V	115V	50%	10.0	7.8	6.0	60%	9.8	7.6	5.8	70%	9.6	7.4	5.6	80%	9.4	7.2	5.4	90%	9.2	7.0	5.2	100%	9.0	6.8	5.0
LOAD	277V	230V	115V																													
50%	10.0	7.8	6.0																													
60%	9.8	7.6	5.8																													
70%	9.6	7.4	5.6																													
80%	9.4	7.2	5.4																													
90%	9.2	7.0	5.2																													
100%	9.0	6.8	5.0																													

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	SHORT CIRCUIT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P: 90VAC I/P: 295VAC O/P: FULL LOAD Ta: 25°C	NO DAMAGE Hiccup mode, recovers automatically after fault condition is removed

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	PWM Power Transistor	Q 1 Rated 800V/9A	I/P: High-Line +3V =298V O/P: (1) Full Load Turn on (2) Output Short (3) Full load continue Ta: 25°C	(1) 656V (2) 624V (3) 582V
2	O/P Diode (MOSFET)	D101 Rated 1000V/5A	I/P: High-Line +3V =298V O/P: (1) Full Load Turn on (2) Output Short (3) Full load continue Ta: 25°C	(1) 500V (2) 222V (3) 196V
3	Control IC	U1 Rated 35V (MAX)	I/P: High-Line +3V =298V O/P: (1) FULL LOAD (2) Output Short (3) Low Line No Load Ta: 25°C	(1) 14.8V (2) 14.7V (3) 14.7V
4	Clamp Diode	D 1 Rated 1000V/1A	I/P: High-Line +3V = 298V O/P: (1) Full Load input on/off (2) Output Short Ta: 25°C	(1) 478V (2) 450V

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	WITHSTAND VOLTAGE	I/P-O/P: 3.75KVAC/min	I/P-O/P: 4.2 KVAC/min Ta: 25°C	I/P-O/P: 1.674mA NO DAMAGE
2	ISOLATION RESISTANCE	I/P-O/P: 500VDC>100MΩ	I/P-O/P: 500 VDC Ta: 25°C/70% RH	I/P-O/P: >9999MΩ

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	EN61000-3-2 CLASS C	I/P: 230 VAC/50HZ O/P: FULL/60% LOAD Ta: 25°C	PASS
2	CONDUCTION	EN55015	I/P: 230 VAC/50HZ O/P: FULL LOAD Ta: 25°C	PASS Test by certified Lab
3	RADIATION	EN55015	I/P: 230 VAC/50HZ O/P: FULL LOAD Ta: 25°C	PASS Test by certified Lab
4	E.S.D	EN61000-4-2 LIGHT INDUSTRY AIR: 8KV Contact: 4KV	I/P: 230 VAC/50HZ O/P: FULL LOAD Ta: 25°C	PASS
5	E.F.T	EN61000-4-4 LIGHT INDUSTRY INPUT: 1KV	I/P: 230VAC/50HZ O/P: FULL LOAD Ta: 25°C	PASS
6	SURGE	EN61000-4-5 LIGHT INDUSTRY L-N: 1KV	I/P: 230VAC/50HZ O/P: FULL LOAD Ta: 25°C	PASS
7	Test by certified Lab & Test Report Prepare			

■ **RELIABILITY TEST**

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																								
1	TEMPERATURE RISE TEST	MODEL: IDPC-45-700 1. ROOM AMBIENT BURN-IN: 2 HRS I/P: 230VAC O/P: FULL LOAD Ta= 30.1℃ 2. HIGH AMBIENT BURN-IN: 2 HRS I/P: 230VAC O/P: FULL LOAD Ta= 45.7℃																																																										
				<table border="1"> <thead> <tr> <th>NO</th> <th>Position</th> <th>ROOM AMBIENT Ta= 30.1℃</th> <th>HIGH AMBIENT Ta=45.7℃</th> </tr> </thead> <tbody> <tr><td>1</td><td>ZNR1</td><td>36.2℃</td><td>49.6℃</td></tr> <tr><td>2</td><td>BD1</td><td>67.3℃</td><td>80.5℃</td></tr> <tr><td>3</td><td>D1</td><td>74.5℃</td><td>88.4℃</td></tr> <tr><td>4</td><td>Q1</td><td>77.9℃</td><td>91.9℃</td></tr> <tr><td>5</td><td>U1</td><td>65.6℃</td><td>78.4℃</td></tr> <tr><td>6</td><td>T1</td><td>78.4℃</td><td>92.3℃</td></tr> <tr><td>7</td><td>C16</td><td>62.0℃</td><td>75.1℃</td></tr> <tr><td>8</td><td>RG1</td><td>76.8℃</td><td>89.7℃</td></tr> <tr><td>9</td><td>D101</td><td>93.1℃</td><td>105.3℃</td></tr> <tr><td>10</td><td>C201</td><td>65.0℃</td><td>78.4℃</td></tr> <tr><td>11</td><td>Q100</td><td>58.9℃</td><td>72.6℃</td></tr> <tr><td>12</td><td>L100</td><td>71.2℃</td><td>85.2℃</td></tr> <tr><td>13</td><td>C106</td><td>61.7℃</td><td>74.6℃</td></tr> </tbody> </table>	NO	Position	ROOM AMBIENT Ta= 30.1℃	HIGH AMBIENT Ta=45.7℃	1	ZNR1	36.2℃	49.6℃	2	BD1	67.3℃	80.5℃	3	D1	74.5℃	88.4℃	4	Q1	77.9℃	91.9℃	5	U1	65.6℃	78.4℃	6	T1	78.4℃	92.3℃	7	C16	62.0℃	75.1℃	8	RG1	76.8℃	89.7℃	9	D101	93.1℃	105.3℃	10	C201	65.0℃	78.4℃	11	Q100	58.9℃	72.6℃	12	L100	71.2℃	85.2℃	13	C106	61.7℃	74.6℃
NO	Position	ROOM AMBIENT Ta= 30.1℃	HIGH AMBIENT Ta=45.7℃																																																									
1	ZNR1	36.2℃	49.6℃																																																									
2	BD1	67.3℃	80.5℃																																																									
3	D1	74.5℃	88.4℃																																																									
4	Q1	77.9℃	91.9℃																																																									
5	U1	65.6℃	78.4℃																																																									
6	T1	78.4℃	92.3℃																																																									
7	C16	62.0℃	75.1℃																																																									
8	RG1	76.8℃	89.7℃																																																									
9	D101	93.1℃	105.3℃																																																									
10	C201	65.0℃	78.4℃																																																									
11	Q100	58.9℃	72.6℃																																																									
12	L100	71.2℃	85.2℃																																																									
13	C106	61.7℃	74.6℃																																																									
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P: 295VAC/90VAC O/P: FULL/80% LOAD Ta= -25℃	TEST: OK																																																								
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 40℃ NO DAMAGE	I/P: 305VAC O/P: FULL LOAD Ta=40℃ HUMIDITY= 95%R.H	TEST: OK																																																								
4	TEMPERATURE COEFFICIENT	±0.03 %/℃(0~40℃)	I/P: 230 VAC O/P: FULL LOAD	±0.01%/℃																																																								
5	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature: -45℃~ +85℃ 2. Temperature change rate : 25℃ / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle: 5 CYCLE 5. Input/Output condition: AC OFF STATIC		TEST: OK																																																								
6	THERMAL SHOCK TEST	1. Thermal shock Temperature: -25℃~ +45℃ 2. Temperature change rate : 25℃ / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle: 16 CYCLE 5. Input/Output condition: 230VAC/Full Load AC ON/OFF TEST AC on 3 sec/AC off 1 sec TEST		TEST: OK																																																								



7	VIBRATION TEST	<p>1 Carton & 1 Set</p> <p>(1) Waveform: Sine Wave</p> <p>(2) Frequency: 10~500Hz</p> <p>(3) Sweep Time: 10min/sweep cycle</p> <p>(4) Acceleration: 2G</p> <p>(5) Test Time: 60min in each axis (X.Y.Z)</p> <p>(6) Ta: 25°C</p>	TEST: OK
8	CAPACITOR LIFE CYCLE	<p>IDPC-45-700: SUPPOSE C106 IS THE MOST CRITICAL COMPONENT</p> <p>(1) I/P: 230VAC O/P: FULL LOAD Ta= 25 °C LIFE TIME</p> <p>(2) I/P: 230VAC O/P: FULL LOAD Ta= 40 °C LIFE TIME</p> <p>(3) I/P: 230VAC O/P: 75% LOAD Ta= 40 °C LIFE TIME</p> <p>(4) I/P: 230VAC O/P: MIN LOAD Ta= 40 °C LIFE TIME</p>	<p>(1) 419576 HRS</p> <p>(2) 178876 HRS</p> <p>(3) 195559 HRS</p> <p>(4) 202008 HRS</p>
9	MTBF	<p>Conducted by Parts Stress Analysis Prediction</p> <p>408.8K hrs min. MIL-HDBK-217F (25°C)</p>	

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	ZHANGZJ/ZHUOKB	SKY	LIUWY