



Interocean EMC Technology Corp.

No.5-2 Lin 1 Tin-Fu Tsun Lin-Kou Hsiang, Taipei County, Taiwan 244 R.O.C
TEL: +886 2 2600 6861 FAX: +886 2 2600 6859

Certificate of Compliance

GENERAL INFORMATION	
Applicant	MEAN WELL ENTERPRISES CO., LTD. No. 28, Wu-Chuan 3 rd Road, Wu Ku Ind. Park, Taipei Hsien, Taiwan
Contact Person	Neil
Tel / Fax Number	+886 2 2299-6100 / +886 2 2299-6200
Manufacturer	MEAN WELL ENTERPRISES CO., LTD.

PRODUCT DESCRIPTION	
EUT Description	Switching Power Supply
Model Number	xLy-60-z (x=C or P, y=G or N, z=12, 15, 20, 24, 27, 36, 48)
Operation Environment	Residential, Commercial & Light Industry

EMC DIRECTIVE 89/336/EEC		
Emission Measurement Standard		
EN 55011	B	Passed
EN 55022 (Radio Frequency)	B	Passed
EN 55015	B	Passed
EN 61000-6-3	B	Passed
EN 61000-3-2 (Harmonic Current)	A/C	Passed
EN 61000-3-3 (Voltage Fluctuations and Flicker)	Per Spec.	Passed
Immunity Measurement Standard (EN 55024, EN 61204-3, EN61000-6-1 and EN61547)		
Basic Standard		
IEC 61000-4-2 (Electrostatic Discharge)	B	Passed
IEC 61000-4-3 (Radiated Field)	A	Passed
ENV 50204 (Radiated Field)	A	Passed
IEC 61000-4-4 (Fast Transients/Burst)	B	Passed
IEC 61000-4-5 (Surge)	B	Passed
IEC 61000-4-6 (Conducted Field)	A	Passed
IEC 61000-4-8 (Power Frequency Magnetic Field)	A	Passed
IEC 61000-4-11 (Voltage Dip/Interruption)	C/B/C/C	Passed

This device has been shown to be in compliance with and was tested in accordance with the measurement procedures specified in the Standards & Specifications listed above and as indicated in the measurement report number: **6A120801E**

This Certificate is hereby issued to the above named company and is only valid for the type of equipment that is identical mechanically and electronically with the unit tested under Compliance Engineering Services' supervision.

Issued By:


Mike Huang / EMC Manager
Interocean EMC Technology Corp.

Date: December 29, 2006