



EC-Conformity Declaration

For the following equipment :

Product Name: Switching Power Supplies

Model Designation: USP-150X ; ULP-150-X (X=12,15,24,36,48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

Low Voltage Directive (2006/95/EC) :

EN60950-1:2006+A11:2009+Am1:2010 LVD certificate No : PSE99-0888

Electromagnetic Compatibility Directive (2004/108/EC) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission	EN55022:2006+A1:2007	Class B
	EN55011:2007+A2:2007 (Group 1)	Class B
	EN61000-6-3:2007	

Harmonic current EN61000-3-2:2006

Voltage flicker EN61000-3-3: 2008

EMS (Electro-Magnetic Susceptibility)

EN55024:1998+A1:2001+A2:2003 EN61204-3:2000 EN61000-6-1:2007

ESD air EN61000-4-2:2009 Level 3 8KV

ESD contact EN61000-4-2:2009 Level 2 4KV

RF field susceptibility EN61000-4-3:2006+A1:2008 Level 2 3V/m

EFT bursts EN61000-4-4:2004 Level 2 1KV/5KHz

Surge susceptibility EN61000-4-5:2006 Level 3 2KV/Line-Line 4KV/Line-Earth

Conducted susceptibility EN61000-4-6:2009 Level 2 3V

Magnetic field immunity EN61000-4-8:1993+A1:2001 Level 2 3A/m

Voltage dip, interruption EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods

Keyed carrier immunity ENV50204:1995 Level 2 3V/m 900MHz

Note:

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure. For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies".(as available on <http://www.meanwell.com>)".

This Declaration is effective from serial number HB01xxxxxx

Person responsible for marking this declaration :

Mean Well Enterprises Co., Ltd.
(Manufacturer Name)

28, Wu-Chuan 3rd Road, Wu Ku Ind. Park, Taipei Hsien, Taiwan R.O.C.
(Manufacturer Address)

Johnny Huang/Senior Verification Engineer :  Ted Cheng/Product Manager : 
(Name / Position) (Signature) (Name / Position) (Signature)

Taiwan Aug.18.2010
(Place) (Date)